



BATANGAS II ELECTRIC COOPERATIVE, INC.

Antipolo del Norte, Lipa City



(043) 756 6337; 757 0951

Daily Supply and Load Demand Outlook			
October 19, 2022			
(MW)	Morning	Afternoon	Evening
	0001H to 1200H	1201H to 1800H	1801H to 2400H
Power Supply	103.33	107.60	106.18
Maximum Load Demand	138.99	144.50	142.06
Power Supply Reserve (Deficit)	35.67	36.90	35.89

Note/s:

The deficit will be source out from WESM as there trading intervals with competitive spot prices.